

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CS0332

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Bosch Thermotechnik GmbH Sophienstraße 30-32, D-35576 Wetzlar
Distributor <i>Vertreiber</i>	Bosch Thermotechnik GmbH Junkersstraße 20-24, D-73249 Wernau
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Gas wall hanging condensing boiler with integrated heat exchanger for domestic hot water (DHW)
Model <i>Modell</i>	Bosch Condens GC2200(i)W
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: B 18/08/2767 EU from 30.08.2018 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	18-0671-GWA

70028-04-A-DE

11.09.2018 Rie A-1/2 

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
GC2200(i)W 24 C23	nominal heat output: 4,8...24,0 kW heat input (Hi): 4,9...24,5 (DHW: ...25,5) kW	
GC2200W 24 C23;	nominal heat output: 4,8...20,0 kW	
GC2200W 20/25 C23	nominal heat input (Hi): 4,9...20,4 (DHW: ...25,5) kW	
GC2200W 15/25 C23	nominal heat output: 4,8...15,0 kW nominal heat input (Hi): 4,9...15,3 (DHW: ...25,5) kW	

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CS0332

Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	Bosch Thermotechnik GmbH Sophienstraße 30-32, D-35576 Wetzlar
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Gas wall hanging condensing boiler with integrated heat exchanger for domestic hot water (DHW)
Model <i>Modell</i>	Buderus Logamax Plus GB022(i)...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: B 18/08/2767 EU from 30.08.2018 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	18-0671-GWA

70028-04-A-DE

11.09.2018 Rie B-1/2 
 Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.



DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Type	Technical Data	Energy Labelling
<i>Typ</i>	<i>Technische Daten</i>	<i>Energieeffizienzkennzeichnung</i>
GB022-24 K H	nominal heat output: 4,8...24,0 kW heat input (Hi): 4,9...24,5 (DHW: ...25,5) kW	
GB022-24 K H	nominal heat output: 4,8...20,0 kW nominal heat input (Hi): 4,9...20,4 (DHW: ...25,5) kW	
GB022i-24 K H	nominal heat output: 4,8...24,0 kW heat input (Hi): 4,9...24,5 (DHW: ...26,5) kW	

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CS0332

Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	Bosch Thermotechnik GmbH Junkersstrasse 20, D-73249 Wernau
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Gas wall hanging condensing boiler with integrated heat exchanger for domestic hot water (DHW)
Model <i>Modell</i>	Junkers Cerapur 2200
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: B 18/08/2767 EU from 30.08.2018 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	18-0671-GWA

70028-04-A-DE

11.09.2018 Rie C-1/2 
 Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.



DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Type	Technical Data	Energy Labelling
<i>Typ</i>	<i>Technische Daten</i>	<i>Energieeffizienzkennzeichnung</i>
GC2200W 20/25 C23	nominal heat output: 4,8...20,0 kW nominal heat input (Hi): 4,9...20,4 (DHW: ...25,5) kW	